

**Copy of the Water Health and Sanitation Certificate Issued Medical Officer,
Health Department, Surat Municipal Corporation**

Dr. P. H. Umrigar
MBBS, DPH
Medical Officer of Health



Surat Municipal Corporation
Muglisara,
Surat – 395 003

No.PHD/PI/10
Dt.02/04/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Mr. J.P.Raval, Sanitary Inspector from Health Department inspected Broadway International School, Situated at Nr Nestwood, Bh. Atlanta shop. Mall, Althan - Bhimrad Canal Road, Althan, Surat, on Dt. 02/04/2026 and on the basis of Water Test report bearing number 40 dated 17/02/2026 of Surat Municipal Corporation (Public Health Laboratory) certified that the **Broadway International School** has Safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31st December-2026.

Pradeep H. Umrigar
Dr. Pradeep H. Umrigar
Medical Officer of Health
Health Department
Surat Municipal Corporation




To,
Principal
Broadway International School,
Nr Nestwood, Bh. Atlanta shop. Mall,
Althan - Bhimrad Canal Road,
Althan,
Surat,

Pradeep H. Umrigar
Principal
Broadway International School
Althan, Surat.

VIDHYAVIHAR FOUNDATION

Pradeep H. Umrigar
DIRECTOR

Copy of the Water Examination Report

	Public Health Laboratory		
	Surat Municipal Corporation 2 nd Floor, Vesu Urban Community Health Center, Opp. Vesu Fire Station, VIP Road, Vesu, Surat - 395007 Gujarat		

Name And Address of Applicant-	Broadway International School Behind Atlanta Mall, Althan Bhimard Canal Road, Althan, Surat-395017			Report No.	No.Q-1/PHL/WC/B-40/2025-26
				Receipt No.	829110-2
				ULR No.	-
				Date of Sample	16/02/2026
Type of Sample:-	Private	Register Entry No.	40	Start Date of Analysis	17/02/2026
Source of the Water:-	Drinking Water (chemical)			End Date of Analysis	17/02/2026

Test Report

Sample Description :- A Plastic Bottle
Physical Appearance: - Clear Liquid

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.	-	Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.	-	Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.	-	7.4	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent	Max. 0.5
6.	Nitrate (as NO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.4	mg/l	Absent	Max. 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	18.0	Max. 250
8.	Total Alkalinity (as HCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	29.0	Max. 200
9.	Total hardness (as CaCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	17.0	Max.200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	64.0	Max. 500

Opinion: With respect to the test and observation performed, above sample of **Drinking Water (Tank Water)** Conforms to the standards and provisions of Food Safety and Standard Act. 2006 and FSS Rules & Regulations.

.....end of the test report.....

Report issue Date :- 20/02/2026



K. A. Mehta
 Food Analyst
 Public Health Laboratory
 Surat Municipal Corporation
 Surat

Note:-
 ♦ Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested.
 ♦ Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.

Page 1 of 1

Sanjana
 Principal
 Broadway International School
 Althan, Surat.

VIDHYAVIHAR FOUNDATION
Sanjana
 DIRECTOR